



STANDARD PRECAST BASE MANHOLE

SECTION
TYPE A
N.T.S.

PRECAST TOP SLAB MANHOLE

SECTION
TYPE B
N.T.S.

NOTE: A
USE TYPE B MANHOLE
WHEN MANHOLE DEPTH IS
5.5 FT. OR LESS UNLESS
CALLED FOR OTHERWISE
ON THE DRAWINGS.

JOINT SEAL MATERIAL,
KENT SEAL MASTIC
ACRYLIC POLYMERIC
SEALANT OR APPROVED
EQUAL. TYP. ALL JOINTS.

NOTES:
1. SEE TYPE A MANHOLE
FOR BASE AND WALL DETAILS.
2. USE TYPE B MANHOLE
WHEN MANHOLE DEPTH IS
5.5 FEET OR LESS UNLESS
CALLED FOR OTHERWISE
ON THE DRAWINGS.

MANHOLE PIPE CONNECTOR
"A-LOCK" OR EQUAL. SEE
SPECIFICATIONS.
MAIN CHANNEL TYP.
PROVIDE FLEXIBLE WATER-TIGHT
JOINT IN PIPELINE 1'-6" FROM
EDGE OF MANHOLE. USE GASKETED
BELL JOINT OR NEOPRENE COUPLING
SUCH AS CAULDER, FERNGO, OR EQUAL
WITH STAINLESS STEEL SHEAR RINGS
(SEE SPECIFICATIONS).
PROVIDE A MIN. OF 6" OF
BEDDING MATERIAL
COMPACTED TO 95% OF
ASTM D-698 DENSITY.

| REVISION | DATE |
|-----------------|--------|
| GENERAL UPDATES | 12/106 |
| | |
| | |

CITY OF
UNION
OREGON

STANDARD SEWER DETAILS
STANDARD PRECAST MANHOLE

FIGURE
S1