



NOTE:
 ALL BACK FILL IN AREA OF WATER-SEWER CROSSING TO A DEPTH 12" ABOVE THE TOP OF THE HIGHEST PIPE SHALL BE 3/4"-0 BASE ROCK COMPACTED TO 95% OF ASTM D-698 LABORATORY DENSITY.

WATER-SEWER CROSSING
 (NEW SEWER LINE CONSTRUCTION)
 N.T.S.

REVISION	DATE	CITY OF UNION OREGON	STANDARD SEWER DETAILS WATER/SEWER CROSSING	FIGURE S7