



- NOTES:**
1. SEE SUPPORT BEAM DETAIL WHEN SUPPORT BEAM IS REQUIRED.
 2. ALL BACK FILL IN AREA OF WATER-SEWER CROSSING TO A DEPTH 12" ABOVE THE TOP OF THE HIGHEST PIPE SHALL BE 3/4"-0 BASE ROCK COMPACTED TO 95% OF ASTM D-698 LABORATORY DENSITY.

WATER-SEWER CROSSING
(NEW WATER LINE CONSTRUCTION)

N.T.S.

| REVISION | DATE | CITY OF UNION OREGON | STANDARD WATER DETAILS WATER-SEWER CROSSING | FIGURE W10 |
|----------|------|----------------------|---|------------|
| | | | | |
| | | | | |
| | | | | |
| | | | | |